

| | | | | | | |
|-------------------------------|-----------------------------------|------|------|------|------|------|
| QUAT SINO | Other cost | 7.63 | | 6.37 | | |
| | Total Lead (Pb) - ug/L | | | | | |
| ROBERT SCOTT | Gym Kitchen | 6.29 | 0.54 | 0.61 | 0.51 | 0.46 |
| | Daycare Kitchen | | 0.99 | 0.98 | 0.81 | 0.79 |
| | Total Lead (Pb) - ug/L | | | | | |
| SCHOOL BOARD | Board Room | 21.9 | 3.97 | 0.29 | | <.20 |
| | Lower Meeting Room | | 0.54 | 0.66 | | <.20 |
| | Total Lead (Pb) - ug/L | | | | | |
| SEA VIEW | Upper Building Drinking Fountain | | 0.36 | 0.26 | 3.19 | |
| | Upper Renovated Classroom | | 0.32 | 2.44 | 0.22 | <.20 |
| | Boys Washroom Drinking Fountain | | 0.35 | 0.2 | 0.34 | |
| | Girls Washroom Drinking Fountain | | 1.18 | 0.83 | 0.46 | |
| | Staff Room | 9.39 | 0.2 | 0.2 | <.20 | 0.36 |
| | Classroom 4 | | 0.8 | 0.38 | 0.78 | 0.5 |
| | Home Ec Room | | 3.56 | 4.73 | 1.55 | 5.3 |
| | Activity Center | 1.73 | 5.42 | 0.85 | 1.19 | 3.3 |
| Total Lead (Pb) - ug/L | | | | | | |
| SUNSET | Gym Kitchen | 8.63 | 0.54 | 0.29 | | <.20 |
| | Boys Room Drinking Fountain | | 0.57 | 0.3 | | 0.23 |
| | Girls Room Drinking Fountain | | 0.66 | 0.29 | | 0.22 |
| | Gym Foyer Drinking Fountain | | 0.53 | 0.2 | | <.20 |
| | Electrical Room Drinking Fountain | | 0.62 | 0.44 | | |
| | Intermediate Drinking Fountain | 4.6 | 0.63 | 0.27 | | |
| | Staff Room | | 0.53 | 0.24 | | <.20 |
| | Washroom by Playground | | 0.55 | 0.25 | | <.20 |
| | Washroom by Driveway | | 0.56 | 0.33 | | 0.21 |
| | Focus Room | | 0.44 | 0.23 | | <.20 |
| Total Lead (Pb) - ug/L | | | | | | |
| TAGAN | Kitchen | 318 | 2.82 | 0.44 | <.20 | 1.04 |
| | Service Entrance | | 9.22 | 6.61 | 0.85 | <.20 |
| | Total Lead (Pb) - ug/L | | | | | |
| WOS S | Staff Room | 2.61 | | | 2.46 | 0.42 |
| | Total Lead (Pb) - ug/L | | | | | |